

EC TYPE EXAMINATION CERTIFICATE

Annex II Paragraph I directive 2009/142/EC



| | | | |
|---------------------------|---------------------|----------------------|------------|
| <i>Certificate number</i> | E1302/5548 - Rev. 2 | <i>Date of issue</i> | 12/10/2011 |
| <i>ID number</i> | 0461BU0940 | <i>Revision</i> | 13/09/2013 |

| | |
|---------------------|-------------------------------|
| <i>Fabricant</i> | I.C.I. CALDAIE S.p.A. |
| <i>Manufacturer</i> | Via G. Pascoli 38, |
| <i>Fabrikant</i> | IT-37050 Santa Maria di Zevio |

| | |
|------------------------|-------------|
| <i>Marque commerc.</i> | ICI CALDAIE |
| <i>Trade mark</i> | |
| <i>Handelsmerk</i> | |

| | |
|--------------|--|
| <i>Type</i> | TNOX BT COND |
| <i>Model</i> | 3000//3500//4000//4100//4800//5000//5100//6000//7000 |
| <i>Type</i> | |

| | |
|-------------------------|---------------------------|
| <i>Genre d'appareil</i> | Condensing boiler |
| <i>Kind of Product</i> | (to be equipped with FDB) |
| <i>Soort toestel</i> | |

| | |
|------------------------|-----|
| <i>Type d'appareil</i> | B23 |
| <i>Appliance type</i> | |
| <i>Type toestel</i> | |


Countries of destination:

AL-AT-BE-BG- CH- CY- CZ- DE- DK- EE- ES- FI- FR-GB-GR- HU-HR
IE- IS - IT- LT- LU- LV- MK- MT- NL-NO- PL-PT- RO- SE- SI- SK- TR

The gas-fired heating boilers may be fitted with any forced draught burner which is CE-marked following the EN 676, if the operating characteristics of the boilers related to the rated heat input and the back-pressure in the combustion chamber are situated within the burner's working range.

Normative references :

This document cancels and replaces the previous one of 09/05/2012


K. De Wit
Director